

487-SLH-TC-P

Application and Performance Specifications

Description: Electromagnetic ballast for (2) fluorescent lamps as indicated below:

• Line Voltage: 277 vac, + 5%, - 10%, 60Hz

Rapid Start

Series Lamp Operation

• High Power Factor

Typical Performance Data									
Lamp		Input Current	Input Power	Power	Ballast	Ballast Efficacy	T.H.D.	Crest	
Туре	#	(Amps)	(Watts)	Factor	Factor	Factor	%	Factor	
F96T12HOES	2	0.75	205	> .98	.91	0.44	< 20	< 1.9	
F96T12HO	2	0.87	237	> .98	.95	0.40	< 10	< 1.7	
F84T12HO	2	0.87	235	> .90	.97	0.41	< 20	< 1.9	
F72T12HO	2	0.74	197	> .90	.96	0.48	< 20	< 1.7	

Application and Performance Specification Information Subject to Change without Notification.

Performance:

- Designed in accordance with ANSI C82.1
- Compatible with PLC and IR systems
- Meets U.S. Public Law 100-357 for energy efficiency
- Meets CSA Standard 654 for energy efficiency
- Lead type circuit

Application:

- Minimum Starting Temperature: 60° F, 15° C for Energy Savings lamps; -20° F, -29° C for other lamps
- Maximum Ballast Case Temperature not to exceed 90° C
- · Sound Rated: B
- Remote Mounting: 15 feet with minimum 18 AWG (refer to TechNote # 7b for other wire sizes/lengths)

Safety:

- No PCB's
- UL listed (Class P, Indoor and Type 1 Outdoor, HL)
- CSA Certified
- · Thermally Protected


Mechanical	 :	Overall	Mounting
Length:		11 3/4"	11 9/64"
Width:		3 3/16"	2"
Height:		2 5/8"	
 Lead Length 	(inches, ± 1):		
	White, Black	18	
	Red (2), Blue (2)	46	
	Yellow (2)	65	
Weight:		12.4 lbs.	

Footnotes:

Warranty

Universal Lighting Technologies warrants to the purchaser that each electronic ballast will be free from defects in material or workmanship for a period of 36 months from date of manufacture when properly installed and under normal conditions of use. Call **1-800-BALLASTx800** for technical assistance.

Manufactured in North America



Ballast must be grounded. Install in accordance with National Electric Code.

^{*} Can be used in any (2) lamp combination of listed lamps.